



## Appendix B

### Certified Validation Report Template, Part A: Provided by Validator

#### Audit Information:

Water Supplier Name:	City of Redding Water Utility	PWS ID:	CA4510005
System Type:	Potable	Audit Period:	Jan1 2019 -Dec 31 2019
Utility Representation:	Candice Bailey-Marlar, Josh Watkins		
Validation Date:	6/16/2021	Call Time:	2PM
		Sufficient Supporting Documents Provided:	Yes

#### Validation Findings & Confirmation Statement:

##### Key Audit Metrics:

Data Validity Score:	69	Data Validity Band (Level):	Band III (51-70)
ILI:	3.71	Real Loss:	74.72 (gal/conn/day)
		Apparent Loss:	16.94 (gal/conn/day)
Non-revenue water as percent of cost of operating system:			
5.8%			

##### Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☐

*If not, rejected recommendations are included here.*

##### Validator Information:

Water Audit Validator:	Amit Sharma	Qualifications:	Water Audit Validator Certificate issued by the CA-NV Section of the AWWA
------------------------	-------------	-----------------	---

Validator Provided